DIMUS IN-CASE HUMIDIFIER
Instructions for Use

Updated March 28, 2011

If your Musafia case is equipped with the Dimus hygrometer/ humidifier system, please note that the hygrometer will indicate relative humidity inside the case (if it is kept closed) or inside the room (if it is kept open). The design of the interior as well as the lining material of the case have been conceived to help keep the humidity stable inside the case. This means that the hygrometer will not react immediately to changes in relative humidity, especially if normally kept closed.

The Musafia dial-type hygrometer has the dial divided into quadrants. The needle will indicate the appropriate quadrant if the air is humid (generally above 70%), normal (between 40% and 70%), or dry (below 40%). The optional digital thermo-hygrometer will indicate the actual relative humidity expressed in percentage.

If the air is humid or normal, no action is necessary. Do not use the humidifier in these conditions. If the hygrometer shows that the air is dry ($< 40\%$), we suggest the following:

1) Remove the humidifier from it's clasps and immerse it completely in warm water in a sink for two minutes.

2) Shake it vigorously to eliminate excess water and dry it with a towel to avoid drippage.

3) Replace the humidifier in it's clasps and close the case with the latch and zippers, leaving the case horizontal (and not standing vertically) for 2-3 hours.

This is sufficient to humidify the interior of the case to safe levels.

Please note: while the humidifier does not require replacement of the filler and will usually last a lifetime, the caps may split with time. Split caps will not change the effectiveness of the humidifier, but if you like you may contact us for free replacements as necessary.